



ENVIROCHEM TESTING LAB & Research Centre

(GOVT. APPROVED LAB)

(An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Lab)

Plot No. 165, 1st Floor, Sector-25, Part-II, HUDA, Panipat-132103, Hr.

M.: +91 90348 91129, 89501 75388, 96719 56782

Email : envirochemtestinglab@gmail.com

Web : www.etlrc.com


TEST REPORT

Report No	ETL/PNP/63689	Report Date	20.09.2025	Doc No.	ETL/QF/7.8/01
Issue to: M/s Haat Supreme Wastech Pvt. Ltd. VPO Bazida Jattan, Karnal		Party's Ref No: Nil Work Order No: 38461 Period of Testing: 16.09.2025-20.09.2025			
SAMPLE PARTICULARS					
1	Name of the Unit	:	M/s Haat Supreme Wastech Pvt. Ltd.		
2	Type of Sample	:	DG stack (45 KVA)		
3	Sampling Point	:	From Top of Silencer		
4	Date of Sampling	:	16.09.2025		
5	Purpose of Analysis	:	Monitoring		
6	Sample Collected by / Supplied by	:	By Lab Representative		
7	Method of sampling	:	IS 11255 (P - 1& 3)		
OBSERVATIONS					
1.	Metering Temperature (°C)	:	33		
2.	Stack Temperature (°C)	:	116		
3.	Velocity (m/sec)	:	9.23		
4.	Source of Emission & capacity	:	DG Stack (45 KVA)		
5.	Diameter of Stack	:	6"		
6.	Height of Stack from Ground Level	:	3'		
7.	Type of Fuel Used	:	LSHS		
8.	Duration of sampling	:	45 min		
9.	Emission Control (if any)	:	Nil		
10.	Fugitive Emission	:	Nil		
11.	General sensory observation	:	Normal		
12.	Recovery of material	:	Nil		

TEST RESULTS

Sr. No.	Parameters	Results	Standard Limits CPCB	Protocol Used
1.	Particulate Matter (PM), (gm/KWh)	0.11	0.2	IS 11255 (Part 1) 1985
2.	Sulphur Dioxide (SO ₂), (gm/KWh)	< 0.05	-	IS 11255 (Part 2) 1985
3.	Oxides of Nitrogen (NO ₂), (gm/KWh)	0.53	4.0	IS 11255 (Part 7) 2005
4.	Carbon Monoxide (CO), (gm/KWh)	0.28	3.5	In-house Method

Remarks: Analysed Parameters meet the Standards Limits.


Manager Lab./ Sr. Chemist

Authorized Signatory
QM / JEM
Date: 
20/09/2025

- N 1. Samples shall be disposed off after 21 days issue of test report unless specified.
O 2. Results listed above related to the tested samples, Endorsement of the same is neither inferred nor implemented.
T 3. The test report shall not be reproduced full or in part & can't be used as proof in the court of law.
E 4. The test report should not be used in any advertising agency/media without the written approval of laboratory