



Report No-1869

Form J

(See Rule 36)

Type of Sample: Legal

Dated:- 20.01.2025

I hereby, certify that I Neeraj Bala Board Analyst duly appointed under sub section (3) of section 53 of the Water (Prevention and Control of Pollution) Act 1974 (06 of 1974), received a sample on the 14th day of January, 2025, collected by Sh. Hardik, AEE accompanied by Sh. Shailender Arora, EE dated 13th day of January, 2025 of M/s Haat Supreme Wastech (P) Ltd, Bajda, Karnal for analysis

Further certify that I have analyzed the above mentioned sample on 14th January-2025 to 20th - January-2025 and declare the result of analysis to be as follows:

Sr. No.	Parameter Name	Result	Result	Limit	Test Method
1.	Sample Code	3642	3643		
2.	Sample Collected from	Inlet of ETP	Outlet of ETP		
3.	Color	Black	Pale Yellow	-	
4.	Odour	Foul	Mild	-	
5.	pH value at 25°C	7.20	6.04	5.5-9.0	APHA 2540 (C)
6.	Biological Oxygen Demand (mg/l)	125.0	7.2 ✓	30	IS 3025 Part 44
7.	Chemical Oxygen Demand (mg/l)	392.0	44.0	250	APHA 5220 (B)
8.	Total Suspended Solids mg/l	182.0	13.0	100	APHA 2540 (C)
9.	Oil and Grease (mg/l)	15.0	BDL(DL=2)	10	APHA 5520 B
10.	Conductivity at 25°C (µS/cm)	7300.0	779.0	-	IS 3025 Part 14
11.	Total Dissolved Solids mg/l	4010.0	428.0	2100	APHA 2540 (C)

Handwritten signature: Hardik AEE
Handwritten signature: Sh. Shailender

The Conditions of the seals, listening and container on receipt was as follows:
Container had its seal found intact and in order, slip on the container had the signature of the representative of the industry and the Board.

Signed this 20th day of January, 2025
Haryana State Pollution Control Board Laboratory,
C-11, Sector-06, Panchkula, Haryana
To

The Member Secretary, HSPCB, Panchkula
CC to Regional Office: Karnal. This test report relate only to the particular sample submitted for testing

Handwritten signature: Neeraj Bala
Board Analyst

End of the Report