



Envirochem Testing & Consultancy LLP

(Formerly known as Envirochem Testing Lab & Research Centre)

(NABL ACCREDITED AND GOVT. APPROVED LAB)

(An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Lab)

Plot No. 165, 1st Floor, Sector-25, Part-II, HUDA, Panipat-132103, Hr.

M. : +91 90348 91129, 89501 75388

Email : envirochemtestinglab@gmail.com

Web. : www.etlrc.com

TEST REPORT

Report No	ETL/ PNP/52788	Report Date	22.07.2024	Doc No.	ETL/QF/7.8/01
Issue to:	M/s Haat Supreme Wash (P) Ltd. Bajida, Karnal	Party's Ref No:	As per agreement	Work Order No:	38790 A&B
		Period of Testing:	17.07.2024-22.07.2024		
SAMPLE PARTICULARS					
1	Type of sample	:	EFFLUENT WATER		
2	Point of Sample Collection	:	ETP Inlet & Outlet		
3	Date & Time of sample collection/ received	:	17.07.2024		
4	Purpose of analysis	:	Monitoring purpose		
5	Sample collected/ supplied by	:	By Lab Representative		
6	Quantity of Sample	:	5 Litre each		
7	Method of Sampling	:	IS 3025 (P – 1) 1987		

TEST RESULTS

Sr. No.	Parameters	Inlet	Outlet	General Std. Limits For Discharge (Inland Surface Water)	Protocol used
1.	Color	Greyish	Colorless	--	IS 3025 (P-4) 1983
2.	Odour	Foul	Mild	--	IS 3025 (P-5) 1983
3.	pH	7.96	7.34	5.5-9.0	IS 3025 (P-11) 1983
4.	COD, mg/L	394	56.7	250	IS 3025 (P-58) 2023
5.	BOD at 27°C for 3 Days, mg/L	121.4	8.9	30	IS 3025 (P-44)2023
6.	Total Suspended Solids, mg/L	165	39.0	100	IS 3025 (P-17) 2022
7.	Total Dissolved Solids, mg/L	1271	1070	2100	IS 3025 (P-16) 2023
8.	Oil & Grease, mg/L	5.8	2.2	10	IS 3025 (P-39) 2021

Remarks: Analysed Parameters meet the General Standards Limits for discharge inland surface water.

*****End Report*****

Verified By
Bilal

Authorised By
Neha Singh
22-07-2024

- N 1. Samples shall be disposed off after 15 days issue of test report unless specified.
O 2. Results listed above related to the tested samples, Endorsement of the same is neither inferred nor implemented.
T 3. The test report shall not be reproduced full or in part & can't be used as proof in the court of law.
E 4. The test report should not be used in any advertising agency/media without the written approval of laboratory