



# Envirochem Testing & Consultancy LLP

(Formerly known as Envirochem Testing Lab & Research Centre)

(GOVT. APPROVED LAB)

(An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Lab)

Plot No. 165, 1st Floor, Sector-25, Part-II, HUDA, Panipat-132103, Hr.

M. : +91 90348 91129, 89501 75388

Email : envirochemtestinglab@gmail.com

Web. : www.etlrc.com

## TEST REPORT

Report No	ETL/ PNP/ 53970	Report Date	21.09.2024	Doc No.	ETL/QF/7.8/01
Issue to: M/s Haat Supreme Wastech Pvt. Ltd. V.P.O. Bazida Kalan , Karnal		Party's Ref No: Nil Work Order No: 39972 Period of Testing: 20.09.2024			
<b>SAMPLE PARTICULARS</b>					
1	Type of sample	:	DG NOISE- (45 KVA)		
2	Date of sample measurement	:	20.09.2024		
3	Purpose of analysis	:	Monitoring purpose		
4	Sample collected/ supplied by	:	By Lab Representative		

### OBSERVATIONS


Sr. No.	Point of measurement	I	II	III	IV	V	VI
1.	Acoustic Enclosure (0.5 m away from DG)	72.5	70.4	71.3	73.2	69.6	71.4

### TEST RESULTS

Sr. No.	Point of measurement	Noise Level (dB)			Standard Limit
		Min.	Max.	Average	(dB)
1.	Acoustic Enclosure (0.5 m away from DG)	69.6	73.2	71.4	75

Remarks: Analysed Parameters meet the Standards Limits.

\*\*\*\*\*End Report\*\*\*\*\*

  
Verified By  
Chemist



Authorized By  
Neha Singh

- N 1. Samples shall be disposed off after 15 days issue of test report unless specified.  
O 2. Results listed above related to the tested samples, Endorsement of the same is neither inferred nor implemented.  
T 3. The test report shall not be reproduced full or in part & can't be used as proof in the court of law.  
E 4. The test report should not be used in any advertising agency/media without the written approval of laboratory