



Envirochem Testing & Consultancy LLP

(Formerly known as Envirochem Testing Lab & Research Centre)

(GOVT. APPROVED LAB)

(An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Lab)

Plot No. 165, 1st Floor, Sector-25, Part-II, HUDA, Panipat-132103, Hr.

M. : +91 90348 91129, 89501 75388

Email : envirochemtestinglab@gmail.com

Web. : www.etlrc.com

TEST REPORT

Report No	ETL/PNP/57439	Report Date	20.03.2025	Doc No.	ETL/QF/7.8/01
Issue to: M/s Haat Supreme Wastech Pvt. Ltd. V.P.O. Bazida Kalan , Karnal		Party's Ref No: Nil Work Order No: 40651 Period of Testing: 20.03.2025			
SAMPLE PARTICULARS					
1	Type of sample	:	DG NOISE- (45 KVA)		
2	Date of sample measurement	:	20.03.2025		
3	Purpose of analysis	:	Monitoring purpose		
4	Sample collected/ supplied by	:	By Lab Representative		

OBSERVATIONS


Sr. No.	Point of measurement	I	II	III	IV	V	VI
1.	Acoustic Enclosure (0.5 m away from DG)	71.4	70.6	71.5	73.3	68.7	71.4

TEST RESULTS

Sr. No.	Point of measurement	Noise Level (dB)			Standard Limit
		Min.	Max.	Average	(dB)
1.	Acoustic Enclosure (0.5 m away from DG)	68.7	73.3	71.0	75

Remarks: Analysed Parameters meet the Standards Limits.

*****End Report*****


Verified By
Chemist



Authorized By
Neha Singh

- N
O
T
E
1. Samples shall be disposed off after 15 days issue of test report unless specified.
 2. Results listed above related to the tested samples, Endorsement of the same is neither inferred nor implemented.
 3. The test report shall not be reproduced full or in part & can't be used as proof in the court of law.
 4. The test report should not be used in any advertising agency/media without the written approval of laboratory